

Questions and answers

„Continued Support to Capacity strengthening of the Veterinary, Phytosanitary and Sanitary Border Inspection, Construction of Border Inspection Posts Bajakovo and Zagreb“

1. Publication reference

EuropeAid/130213/M/WKS/HR

2. Procedure

Open

3. Programme

IPA

4. Financing

National Programme for Croatia under the IPA – Transition Assistance and Institution Building Component for 2008

5. Contracting authority

Central Finance and Contracting Agency

QUESTIONS	ANSWERS
<p>Q 1. Date: 25 August 2010</p> <p><i>Dear Sir,</i></p> <p><i>Please send us written answer to the following question regarding the Bill of Quantities:</i></p> <p><i>- BIP Zagreb Airport, BoQ- Electric system – A1 Supply network-Item 10</i></p> <p><i>Are parameters in connection with above mentioned item correctly listed or it came to a mistake while writing parameters in this item, i.e. are the characteristics of mobile UPS unit power rated at 500 kVa, with 5 minutes autonomy (8 pcs)Is this parameter ok?</i></p>	<p>A 1.</p> <p><i>After review of the chapter A Electric System part I Supply Network, Item 10 of the BoQ for BIP Zagreb Airport typing mistake is revealed. Correct wording in description of the Item should be :</i></p> <p><i>“Delivery and installation of mobile UPS unit power rated at 500 VA, with 5 minutes autonomy”</i></p> <p><i>Contracting Authority intends to remedy this omission by means of Corrigendum No. 2 which will be published on the CFCA web site.</i> <i>(http://www.safu.hr/en/tenders)</i> <i>http://www.safu.hr/en/tenders?category=17&type=&status=&pg=3&sort_by=0</i></p>
<p>Q 2. Date: 27 August 2010</p> <p><i>Respected,</i></p> <p><i>Our available certificate to built Public Works in Spain is the Spanish F Category (maximum) in C Group. See enclosed file if necessary. We would like to know if there are some special qualifications for this tender not included in our</i></p>	<p>A 2.</p> <p><i>Please note that we cannot assess your document during the Tendering phase. All information/documents submitted with a Tender shall be examined by the Evaluation Committee and Evaluation Committee shall decide about compliance of the documentation. Please refer to</i></p>

Questions and Answers

<p><i>available certificate.</i> <i>We hope your answer as soon as possible.</i></p>	<p><i>the Article 22 Evaluation of Tenders and 25 Notification of Award, Contract Clarifications of the Instructions to Tenderers.</i> <i>All the requirements/criteria for participation are given in the Tender Dossier, Volume 1, Section 1, Instructions to Tenderers, Article 3 Participation and Article 12. Information /Documents to be supplied by the Tenderer.</i></p>
<p>Q3. Date: 24 August 2010</p> <p>MECHANICAL INSTALLATIONS BAJAKOVO</p> <p><i>Architectural drawing 03 – cooling chambers 2,3,11 and 12.</i> <i>The temperatures, number of cooling systems do not match the number and purpose/use defined on the BoQ. Please clarify!</i></p>	<p>A 3.</p> <p><i>After review of the temperatures written on architectural drawing 03 of BIP Bajakovo design documentation calculation mistake is revealed. Changes (quantity and new item) shall be officially introduced through Corrigendum to Tender No 2 that shall be published on EuropeAid and SAFU web pages with following amendments</i> Chapter:</p> <p>B. MECHANICAL WORKS</p> <p>I. INSTALLATIONS OF VRV SYSTEM AND AIR CONDITIONING WITH HRV SYSTEM</p> <p><i>Item 42 1 piece of equipment must be added to be a total of 2 pieces.</i></p> <p><i>Item 43 changes to the description of the item and 1 piece must be subtracted to form a total 1 piece.</i></p> <p>New description is:</p> <p><i>Refrigeration split system of -10°C for the cooling chamber of 128 m3 storage capacity; cooling capacity at least 9.5 kW; evaporation temperature -20°C. The kit shall include all items as per technical specification.</i></p> <p><i>Item 44 1 piece must be subtracted to form a total 1 piece.</i></p> <p><i>Item 45 whole item should be completely removed.</i></p> <p><i>Item 47 quantity should be upgraded with a 120m² to be a total of 240 m².</i></p> <p><i>Contracting Authority intends to remedy this omission by means of Corrigendum No. 2 which will be published on the CFCA web site.</i> <i>(http://www.safu.hr/en/tenders)</i> <i>http://www.safu.hr/en/tenders?category=17&type=</i></p>

Questions and Answers

	<p>&status=&pg=3&sort_by=0</p>
<p>Q 4. Date: 24 August 2010</p> <p><i>El. Installations BAJAKOVO Section II, Distribution cabinets, item 14 Delivery and installation of UPS device. Question:</i></p> <ol style="list-style-type: none"> 1. of what power (6 kWA?) 2. autonomy (45min?) 3. which inlet 220V or 380V (220) 4. which outlet 220V or 380v (220) 	<p>A 4.</p> <p><i>El Installations Bajakovo, BoQ Chapter A Electric System, Section II Distribution cabinets, item 14:</i></p> <p>Delivery and installation of UPS with the following characteristics:</p> <ol style="list-style-type: none"> 1. 6 kVA 2. autonomy 45 minutes 3. Input voltage: single-phase, 230 V (220 / 240 V, optional) 4. Output voltage: 230 V sine (220/ 240V) <p><i>Please refer to the Technical Specification for Construction site Bajakovo –Chapter 13.17</i></p>
<p>Q 5. Date: 24 August 2010</p> <p><i>ZAGREB AIRPORT Section I, SUPPLY NETWORK – item 10 Mobile UPS device 500 kVA with 5 minute autonomy</i></p> <p><i>Question:</i></p> <ol style="list-style-type: none"> 1. is it mobile diesel el. generator? 2. “offer single unit price based on qty. 8 pcs delivery”? Please clarify! 3. which inlet is it, if it is UPS device, 380 V or 220 V? 4. which outlet is it, if it is UPS device, 380 V or 220 V? 	<p>A 5.</p> <p><i>ZAGREB AIRPORT Section I, SUPPLY NETWORK – item 10 Mobile UPS device 500 VA with 5 minute autonomy</i></p> <p><i>Answers:</i></p> <ol style="list-style-type: none"> 1. It is not mobile diesel generator, but mobile UPS (500 VA) shall be connected to the diesel –generator set network 2. Quoted sentence must be deleted. Measure unit shall be changed. Instead od „Lump sum“ for 8 pcs delivery, new measure unit shall be „piece“ and new quantity shall be „8“. 3. Input voltage is 220 V. 4. Output voltage is 220 V. <p><i>Please refer to the Corrigendum No 2. that shall be published on the CFCA web site (http://www.safu.hr/en/tenders) http://www.safu.hr/en/tenders?category=17&type=&status=&pg=3&sort_by=0</i></p>
<p>Q 6. Date: 24 August 2010</p> <p><i>In the BoQ for BIP Bajakovo - in Chapter E Civil Works: Part X Doors, Windows, Gates and</i></p>	<p>A 6.</p> <p><i>Although information given in the BoQ are sufficient to give an adequate offer for doors and</i></p>

IPA 2008: „ Continued Support to Capacity strengthening of the Veterinary, Phytosanitary and Sanitary Border Inspection, Construction of Border Inspection Posts Bajakovo and Zagreb“

Questions and Answers

Fences in description of items from 1 to 27 there are references to the schemes of those items, but schemes are not included in the Tender Dossier. Clarify?

windows, due to the reference written within the items description, schemes of doors and windows for BoQ Bajakovo shall be introduced to tenderers. Schemes of doors and windows for Construction site BIP Bajakovo shall be published as a separate file (sheme-bajakovo-pdf) on the following address (<http://www.safu.hr/en/tenders>) (http://www.safu.hr/en/tendershttp://www.safu.hr/en/tenders?category=17&type=&status=&pg=3&sort_by=0)